



### **ADDENDUM NO. 1**

Date: February 4, 2022

Issued by: Sacramento City Unified School District

**Project: 452-1, COVID Drinking Fountain Upgrades – Bid Package 1**

You are hereby notified of the following changes, clarifications, or modifications to the original Contract Documents, Specifications, and Drawings. This Addendum shall supersede the original project documents, and shall take precedence over anything to the contrary therein. All Addenda shall be acknowledged in the Bid Form. Failure to do so may result in disqualification of the bid. All other conditions remain unchanged.

---

#### DRAWINGS

##### A. Sheet A0.2, Typical Mounting Heights and Details

1. General Notes: ADD Note 8. to read "Remove the (E) angle stop valves that were serving the demolished drinking fountains and replace with (N) angle stop valves to accommodate 9(iw)157ctp5 11.04 Tf.a3Msha13( )-4(g16.2)-14(i)5(ca)13(t)-4(i)(0.2)