



Business Services  
Contracts Office  
5735 47th Avenue Sacramento, CA 95824  
(916) 643-2464

*Gerardo Castillo, Chief Business Officer*  
*Kimberly Teague, Contract Specialist*

## **ADDENDUM NO. 2**

Date: May 26, 2017

Issued by: Sacramento City Unified School District

**Project: HVAC, Roofing & Lighting at Washington ES**

You are hereby notified of the following changes, clarifications, or modifications to the original Contract Documents, Specifications, and Drawings. This Addendum shall supersede the original project documents, and shall take precedence over anything to the contrary therein. All Addenda shall be acknowledged in the Bid Form. Failure to do so may result in disqualification of the bid. All other conditions remain unchanged.

---

### **SPECIFICATIONS**

Item No. AD-1.1:      Reference Section 23 80 00, Heating, Ventilating, & Air Conditioning

A. Delete Subparagraph 2.03.A.1, substitute therefor:

1. AAON, to match District Standard. York rooftop air conditioning units will be an acceptable substitution. York units, if submitted, shall be equal in all performance specs to the specified AAON units, and shall be provided with all options and features specified in the Air Conditioning Unit Schedule on Sheet M0.2 and in Specification Section 238000. Roof curbs shall have a current OSHPD OPA number. Bidders shall include in their bid any additional work required to accommodate the York units, such as different duct-through-roof orientation than AAON, different electrical power characteristics, different weight, etc.

Item No. AD-1.2:      Reference Section 27 60 00, Assistive Listen System

A. Delete Paragraph 1.01.A, substitute therefor:

A. Provide a complete Assistive Listening System capable of broadcasting audio to MP Room. The Assistive Listening System shall be a permanent system connected to the sound systems with 17 receivers. The interconnection of the two systems shall not void any warranties.

**END OF ADDENDUM NO. 2**